CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

- I C

LISTING SERVICE

LISTING No. 7315-1214:103 Page 1 of 1

CATEGORY: Power Units

LISTEE: Alarm Saf, 65 A Industrial Way, Wilmington, MA 01887-3499

Contact: *Joe Holland (978) 658-6717

DESIGN: Models AS/MPS-U12030-B03-UL, AS/MPS-U12030-B04-UL,

AS/MPS-U24030-B03-UL and AS/MPS-U24030-B04-UL regulated power supply/battery charger units. Unit is capable of charging batteries as large as 34 Ah and the power supply output is rated at 3 A maximum. Refer to listee's data sheet (52-140) for detailed

product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances

and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number designation and UL label.

APPROVAL: Intended as regulated and power limited power supply units to provide auxiliary power.

*Rev. 06-15-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: JUNE 15, 2002 Listing Expires June 30, 2003

Authorized By: **DIANE K. AREND**, Senior Deputy

Program Manager